

Shandong Huayou Water Treatment Technology Co., Ltd.

TEL:0086-531-88873616 FAX:0086-531-88686116 WEB:www.sdhykj.com

Certificate of Analysis

ATMP (liquid)

Product Name: ATMP	Batch No.: 20161013	
Place: Factory	Sample quality: 500ml	
Test Item	Standard	Result
Appearance	Colorless or amble transparent liquid	Colorless transparent liquid
Solid content % \geq	35.0	50.21
PH (1% Water Solution) \geq	9.0	10.24
Density (20°C) g/cm ³ \geq	1.22	1.30
Analyst: Ms.Yin	Checker: Ms.Yuan	
Identification: Qualified	Time	2016-10-13